

FIDS Symposium 2014

# The River Bender




TransAlta

# Bow River Simulation Model






# Location






# Cumulative Annual Volume - Bow River at Calgary





# Annual minimum flow - Bow River at Calgary








# Bow River Reservoirs – Existing Operations

**Total active storage = 0.56 M ac-ft**  
**Normal storage variability = 0.30 M ac-ft**  
**Minimum carry-over storage = 0.10 M ac-ft**



**Reported numbers:**

1. MW generation capacity
2. ac-ft active storage between LSL and FSL
3. cfs max flowby through the power plant



# Model Interface



Find

Run

Restore Defaults



TRANSALTA BOW RIVER FLOW AUGMENTATION FEASIBILITY STUDY



Graphs / Outputs

Model Units

Acronyms

## INITIAL WATER LEVELS

Initial comfort **HELP**

ML Initial WL 1,471.45

SL Initial WL 1,891.04

UK Initial WL 1,894.70

LK Initial WL 1,881.19

BF Initial WL 1,370.56

KF Initial WL 1,279.28

HS Initial WL 1,255.71

GF Initial WL 1,188.05

**NOTE:**  
Click on the HELP or ? buttons for further information about the various interface controls.

**CONTACT:**  
Michael\_Bender@Golder.com  
Apurva\_Gollamudi@Golder.com

## LOWER COMFORT ZONE CURVES

**HELP**

ML Lower CZ

SL Lower CZ

GF Lower CZ

UK Lower CZ

LK Lower CZ

BF Lower CZ

## GATE CONTROLS

**HELP**

Master SG Control **Master Sluice Gate Control**

UK SG Control

BF SS Control

KF RG Control

BF SG Control

KF SS Control

HS GS Control

HS OFS Control

HS SG Control

GF OFS Control

GF SG Control

## SLUICE GATE OPERATION RULES

**HELP**

UK SG Rule

BF SG Rule

GF SG3 Rule

GF SG Rule

## FLOOD / DROUGHT RESPONSE RULE

**HELP**

Ghost Water Level Rule

Bow flood response rule

Normal operation

Emergency release rule

Banff Flow Response Rule

Inflow Response Rule

## GRAPHICAL RULES FOR POWERPLANT OPERATIONS

**HELP**

Caso Emerg Release Rule

Caso Augment Rule

Caso Normal Op Rule

Caso Bow Flood Rule

Qmin Caso Summer cfs

Qmin Poca cfs

Qmin Ghost Summer cfs

Qmin Caso Winter cfs

Qmin Barr cfs

Qmin Ghost Winter cfs

Spray Emerg Release Rule

Spray Augment Rule

Spray Normal Op Rule

Spray Bow Flood Rule

Barr Emerg Release Rule

Barr Augment Rule

Barr Normal Op Rule

Barr Bow Flood Rule

Ghost normal rule

Inter Emerg Release Rule

Inter Augment Rule

Inter Normal Op Rule

Inter Bow Flood Rule

Poca Emerg Release Rule

Poca Augment Rule

Poca Normal Op Rule

Poca Bow Flood Rule

Ghost Augment rule

## AUGMENTATION RULE CHOICE

**HELP**

Augmentation Switch

Bassano Flow Trigger cfs

Augment Start

Augment End




# Operating Rules

- **iThink (Stella) Simulation Model**

- Daily inflows (1990-2010), no intra-day peaking.

- **Dynamic rules determine daily release as a function of:**

- Current reservoir levels (no forecast)
- Power plant flowby capacity (normal operations and augmentation periods)
- Spill gates, spillways, stop log operations
- Flood response, drought response








Bow River Simulation Model

# Summer Flow Augmentation



# Bow River System Summary

## Seasonal release volumes from Ghost Reservoir (ac-ft)



## Bow River Storage Characteristics

Average annual cumulative flow volume


- Bow at Calgary = 2,350,000 acre-ft
- Bow at Banff = 940,000 acre-ft
- Tributaries upstream of Ghost = 1,390,000 acre-ft

Total active storage = 560,000 acre-ft

Typical storage variability in a year = 300,000 acre-ft



# Potential for Augmentation





# Flow Augmentation Target at Bassano (April to October, acre-ft)


Year	Historical Release from Ghost	Modelled Release (Bassano Augmentation)	Augmentation Compared to Historical	Augmentation Target to Maintain 800 cfs at Bassano	Number of Days that Augmentation Rule is Triggered
1991	2,191,100	2,244,000	52,900	34,711	35
1992	1,479,100	1,523,000	43,900	68,430	69
1993	1,792,900	1,886,700	93,800	0	0
1994	1,440,500	1,518,100	77,600	95,207	96
1995	1,916,900	2,019,800	102,900	28,760	29
1996	1,862,400	1,942,900	80,500	30,744	31
1997	1,676,600	1,771,200	94,600	39,670	40
1998	1,714,900	1,810,500	95,600	55,537	56
1999	1,851,800	1,896,300	44,500	16,860	17
2000	1,410,300	1,489,700	79,400	120,992	122
2001	1,204,900	1,269,500	64,600	163,637	165
2002	1,700,000	1,771,700	71,700	35,703	36
2003	1,489,800	1,573,400	83,600	105,125	106
2004	1,681,000	1,777,800	96,800	30,744	31
2005	2,064,300	2,148,000	83,700	13,884	14
2006	1,508,900	1,536,700	27,800	27,769	28
2007	1,922,400	2,004,000	81,600	3,967	4
2008	1,873,900	1,950,500	76,600	0	0
2009	1,379,300	1,415,700	36,400	4,959	5
2010	1,360,300	1,450,600	90,300	8,926	9
<b>AVG.</b>	<b>1,676,065</b>	<b>1,750,005</b>	<b>73,940</b>	<b>44,281</b>	<b>45</b>

Note: 70,000 ac-ft (12%) modelled active storage remaining at end of winter 2002.




# Model Output: Total Storage


### Historical Actual




### Bassano Augmentation Scenario



### Model – Normal Ops (approximate historical)



### Bassano Augmentation + LK Stabilized





---

## Summary of Findings

---

- Augmentation of about 80,000 ac-ft can be achieved, on average.
  - Average increase in summer flow at Ghost ~ 225 cfs
  - Winter flows through Calgary can be maintained at ~ 1250 cfs
  - Total storage will only be utilized in a flood year
- Downstream licensees' demands cannot be met in dry years (~1 in 10).
  - In 2001, the augmentation requirement was >160,000 ac-ft
  - Realistically, about 60,000 ac-ft could have been guaranteed
- Requires TransAlta to change the way their reservoirs are operated.
  - Potential impacts to recreational users (Kananaskis River, Ghost Lake)



Bow River Simulation Model

# **Additional Flood Control**









FIDS

# Memories

May 30, 2014


































May 30, 2014









May 30, 2014



SKOKI

