




Dual Drainage Assessment

Shohan Ahmad, PhD, PENG




Study Area






Storm Sewershed






Major Drainage Areas





Hydrologic Modelling (DDSWMM)





Impervious Surfaces






Inlet Types







Level of Service Analysis Areas




Hydraulic Analysis (Infoworks CS)




Hydraulic Analysis (Infoworks CS)



Hydraulic Analysis (Infoworks CS)




Hydraulic Analysis (Infoworks CS)






Existing ROW Capacity






Alternative #2 ICD Program @ 15L/s






Alternative #3 ICD Program & Selective LPC @ 15L/s






Alternative #4 Pipe Upgrade






Results: Ponding Areas LP1





Results: Ponding Areas LP2



**Bilberry / Champlain
Dual Drainage Assessment**

Legend


- Primary Spill Path
- Potential Spill Path
- Buildings at Flood Risk
- Buildings at Flood Risk (With Climate Change)
- Maximum Potential Static Ponding Extent
- Dynamic Ponding Extents
- Dynamic Ponding Extents (With Climate Change)
- Storm Manhole
- Catch Basins
- Contours

0 0.025 0.05 km

Preferred Alternative Low Point Figure 2



Results: Ponding Areas LP3






Results: Ponding Areas LP4






Results: Ponding Areas LP5






Results: Ponding Areas LP6






Results: Ponding Areas LP7





Results: Ponding Areas LP8





Results: Minor System



Results: Minor System Level of Service

LEVEL OF SERVICE ANALYSIS
BILBERRY / CHAMPLAIN DUAL DRAINAGE ASSIGNMENT
 CITY OF OTTAWA

IMPLEMENTATION COSTS ⁵	TRUNK SEWERS ¹				LOCAL SEWERS ¹											
	T1	T2	T3	T4	L1	L2	L3	L4	L5	L6	L7	L8	L9	L10	L11	
	TRUNK SERVICE				T1	T1	T1	T3	T3	T1	T2	T2	T4	T4	T3	
EXISTING CONDITIONS	\$ -	2	10	10	100	5	2	100	2	2	50	2	0	0	5	
EXISTING CONDITIONS - STRESS TEST FOR CLIMATE CHANGE	\$ -	2	10	10	< 100	100	5	2	100	2	2	50	2	0	5	
ALT #1 EXISTING CONDITIONS																
Minto Release Rate = 100L/s	\$ -	2	10	10	100	100	5	2	100	2	2	50	2	0	5	
ALT #2 ICD PROGRAM @ 15L/s																
Minto Release Rate = 100L/s		2	25	10	100	100	10	2	100	2	2	100	2	2	0	10
Minto Release Rate = 200L/s	\$ 205,427	2	25	10	100	100	10	2	100	2	2	100	2	2	0	10
Minto Release Rate = 300L/s		2	25	10	100	100	10	2	100	2	2	50	2	2	0	10
Minto Release Rate = 350L/s		2	25	5	100	100	10	2	100	2	2	25	2	2	0	10
ALT #3 ICD and SELECTIVE LPC PROGRAM @ 15L/s, 25L/s and 50L/s																
Minto Release Rate = 300L/s	\$ 208,677	2	25	10	100	100	10	2	100	5	2	100	2	2	0	10
Minto Release Rate = 350L/s		2	25	10	100	100	10	2	100	5	2	50	2	2	0	10
Minto Release Rate = 400L/s		2	25	10	100	100	10	2	100	5	2	25	2	2	0	10
ALT #4 MINOR SYSTEM IMPROVEMENTS ^{2,3}																
T1 Champlain - 95m Outlet Upgrade	\$ 319,827	2			100	10	2			5						
T1 Champlain - 270m Pipe Upgrade	\$ 524,577	5			100	25	5			5						
T1 Champlain - 360m Pipe Upgrade	\$ 635,727	25			100	25	5			5						
T1 Champlain - 360m (with upgraded outlet)	\$ 668,677	100			100	25	5			5						
T1 L2 Champlain - 75m Pipe Upgrade	\$ 727,677					100										
T1 L3 Juniper - 84m Pipe Upgrade	\$ 760,677						100									
T1 L6 Terranova - 220m Pipe Upgrade	\$ 903,677									100						
T2 L8 Chateau - 121m Pipe Upgrade	\$ 347,677		25									10				
T3 Beauclaire - 380m Outlet&Pipe Upgrade	\$ 1,120,677		10					100	5						100	
T3 L5 Grenoble - 215m Pipe Upgrade	\$ 1,342,677		10					100	100						100	
T4 L9 Jeanne D'Arc - 370m Pipe Upgrade	\$ 605,677												50			
T4 L10 Avignon - 145m Pipe Upgrade	\$ 368,177													0		
T4 L10 Avignon - 230m Pipe Upgrade	\$ 621,177													50		
TOTAL OF ALL MINOR SYSTEM IMPROVEMENTS	\$ 2,977,677	100	25	10	100	100	100	100	100	100	50	10	50	50	100	
STRESS TEST FOR CLIMATE CHANGE		< 100	25	10	< 100	100	< 100	100	< 100	100	50	10	50	50	< 100	

- NOTE: 1. Level of service is based on available freeboard within sewer. If freeboard is greater than or equal to 2 mbgs, service is deemed to be adequate.
 2. Minor System Improvements² builds upon the ICD and Selective LPC Program by upgrading pipe sizes to provide additional level of service.
 3. A recommended release rate for the Minto Development at 350L/s is carried forward for all subsequent iterations.
 4. Major system storage provided in depressed areas within open space land use types. Includes all previous improvements from above.
 5. Implementation costs are cumulative to achieve the noted level of service. I.e. All minor system improvement costs incorporate the costs of ICD Programs. Incremental costs are provided in a separate Class D Cost Estimate in the appendices.



Results: Major System Level of Service

LEVEL OF SERVICE ANALYSIS - PONDING AREAS BILBERRY / CHAMPLAIN DUAL DRAINAGE ASSIGNMENT CITY OF OTTAWA

SEWER SERVICE	EXISTING LOW POINTS ¹														PROPOSED LOW POINTS ²	
	B005	C025	D030	D115	D210	D240	D290	D295	D385 ³	D405	D435	D440 ³	D450	D460 ³	D430	D220
EXISTING CONDITIONS	L6 10	L6 10	L7 2	L7 100	T3 10	L7 100	L8 100	L5 100	L5 100	L10 100	L10 10	L11 100	L11 25	T3 100	n/a	T3 n/a
ALT #1 EXISTING CONDITIONS Min to Release Rate = 100L/s	10	10	2	100	25	100	100	100	100	100	10	100	100	25	100	n/a
ALT #2 ICD PROGRAM @ 15L/s PLUS MAJOR SYSTEM IMPROVEMENTS	100	10	2	100	10	100	100	100	100	10	100	100	100	100	100	100
ALT #3 ICD and SELECTIVE LPC PROGRAM @ 15L/s, 25L/s and 50L/s PLUS MAJOR SYSTEM IMPROVEMENTS	100	10	2	100	10	100	100	100	100	10	100	100	100	100	100	100
MINOR SYSTEM IMPROVEMENTS ⁴	100	10	2	100	10	100	100	100	100	10	100	100	100	100	100	100

LEGEND: 100 Increase in Level of Service compared to existing conditions.
25 Decrease in Level of Service compared to existing conditions.

- NOTE:
- Level of service is based on ponding depths that could increase risk of surface flooding to private property. If no risk to private property exists, service is deemed to be adequate.
 - Level of service within proposed low points is based on available storage and impact on downstream private properties.
 - If required storage is less than or equal to storage provided and impact to downstream private properties is reduced, service is deemed to be adequate.
 - Since none of the minor system improvements (in terms of pipe upgrades), will increase the level of major system service, this row is provided for consistency/presentation purposes only.
 - Major system storage provided in depressed areas within open space land use types. Includes all previous improvements from above.
 - When subjected to a stress test for climate change, existing level of service is less than 1:100 years.